



STA = 72 P.S.I.  
RES = 32 P.S.I.

STA = 98 P.S.I.  
FLOW = 1265 G.P.M.

Material List:

6" D. I. Pipe	-	335'
2" Galv. Pipe	-	770'
6" Valves	-	2
2" Valves	-	4
Fire Hydrant	-	1

NOTE: 2" VALS OPEN LEFT  
6" VALS OPEN RIGHT  
F. HYD TO BE 3-WAY & OPEN RIGHT

Paris Point Development Co., a  
to *Partnership*  
Commissioners of Public Works  
of the City of Greenville, S. C.  
May 22, 1981  
Block Book 463-1-15

PARIS POINT  
JAN 1981 SCALE 1" = 400'

RECORDED JUN 12 1981 at 9:55 A.M.

3-1-161

4328 RV-2