



STATIC = 109 PSI.
RES. = 103 PSI.

STATIC = 123 PSI.
FLOW = 2300 GPM

NOTE 8" & 6" VALS OPEN RIGHT,
2" VALS. OPEN LEFT, FIRE
HYD TO BE 3-WAY & OPEN
RIGHT

✓ EASEMENT
Central Realty Corporation
to
Commissioners of Public Works
of the City of Greenville, S.C.
February 20, 1984
Pt. of BB 533.4-1-7.2

BI-LO STORE

OCT, 1983 SCALE 1" = 400'
REV
NOV, 1983

35993

RECORDED MAY 15 1984 (at 4:54 PM).

