

1694
328

DESCRIPTION

- . CONDUIT EMT 1.25"
- . CONDUCTOR CU #12
- . CONDUCTOR CU #10
- . CONDUCTOR CU #1
- . CONDUCTOR CU #6
- . CONDUCTOR CU #4
- . DOUBLE DUPLEX
- . JUNCTION BOX
- . HEAVY DUTY RECEPTACLE
- PANELBOARD "PF2" 120/208 225A
- . MOTOR CONNECTION 3HP
- . MOTOR CONNECTION 1.5 HP
- . MOTOR CONNECTION 2HP
- . MOTOR CONNECTION .75 HP
- KITCHEN COOLER TOWER CONNECT
- . TOGGLE SWITCH 30A
- . CONDUIT EMT .5"
- . CONDUCTOR CU #12
- . CIRCUIT 20A 1P
- KITCHEN WATER HEATER SWITCH
- . CONDUIT EMT .5"
- . CONDUCTOR CU #12
- . CIRCUIT 20A 1P
- KITCHEN COOLER PUMP SWITCH
- . MOTOR CONNECTION .333 HP
- . CONDUIT EMT .5"
- . CONDUCTOR CU #12
- . CIRCUIT 20A 1P
- CAFETERIA CONDUIT EMT 1.5"
- . CONDUCTOR CU #6
- . CONDUCTOR CU #1
- . CIRCUIT 60A 3P

EMERGENCY GENERATOR SYSTEM
EMERGENCY GENERATOR SYSTEM

LIGHTNING PROTECTION SYSTEM
AIR TERMINAL
. COPPER CABLE

17862

RECORDED DEC 13 1984 at 2:38 P.M.

1694
328