



HYDRAULIC GRADIENT = 1160-1177

MATERIAL LIST: BOOK 1150 PAGE 280

8" D. I. Pipe	-	3,040'±
6" D. I. Pipe	-	1,040'±
2" Galv. Pipe	-	2,765'±
8" Valves	-	2
6" Valves	-	7
2" Valves	-	8
Fire Hydrants	-	5

NOTE: 6" & 8" VALS. OPEN RIGHT  
 2" VALS OPEN LEFT  
 FIRE HYDS. TO BE 3-WAY & OPEN RIGHT

**OAK HOLLOW SEC. 1, 2, 3**

BLK. BOOK 498.1-1-54.1, 55.1,  
 56, 56.1, 61.1

A & R Associates, Inc.  
 to  
 Commissioners of Public Works  
 of the City of Greenville, S. C.  
 February 10, 1981  
 BLK. BOOK 498.1-1-56 & 498.7-1-1 thru 76

MAY, 1972  
 REVISED AUG., 1980

RECORDED JUN 19 1981 at 11:29 A.M.

351-17

0.280

4328 RV-2