



BOOK 1158 PAGE 267

NOTE 6" VALS OPEN RIGHT, 2" VALS OPEN LEFT, FIRE HYD. TO BE 3-WAY & OPEN RIGHT.

Material List:

6" D. I. Pipe	-	1,080'±
2" Galv. Pipe	-	810'±
6" Valves	-	3
2" Valves	-	7
Fire Hydrant	-	1

Pebblepart, Limited

to

Commissioners of Public Works,  
of the City of Greenville, S. C.

November 15, 1981 (EXH. 300-3-2)

PEBBLECREEK PH. X SEC. I

OCT 1981 SCALE 1"=400

4328 RV-2

0 2 6 7