

Plat Book-EE-Page 16

PRO. TRACK TO SERVE
 Smith & Brooks, Inc.
 D.S. to C.P. 150'
 C.P. to R/W 285'
 R/W to ENCL. 333'
 768'

PRO. 2" GAS MAIN
 FOR TOWN OF
 FOUNTAIN INN, S.C.
 TO BE PLACED
 5' BELOW GRADE

PREVIOUS GAS MAIN FOR TOWN OF FOUNTAIN INN, S.C.
 TO BE PLACED 5' BELOW GRADE

FOUNTAIN INN, S.C.
 Scale: 1" = 100'

PROPOSED 2" GAS MAIN ENCASED IN 4" VENTED
 STEEL CASING WITH TRACER(S) CASING TO
 EXTEND 183' - 65' AT 118' DIA. MINIMUM DEPTH
 4.5' BELOW BASE OF RAIL OR 1 FT. BELOW
 ROAD BED DITCH WHERE THE GOVERNS
 FOR TOWN OF FOUNTAIN INN, S.C.

DEC 31 1956

103112

109

FOUNTAIN INN, S.C.

Scale 1" = 100'

No Substandard Clearance
 Surveyed 9-56 By [Signature]

BAD COPY

5
 CHAK

32007 31 Dec 15 57
 Lee [Signature] EE 16
 [Signature]

