



BOOK 1137 PAGE 814

STA = 67 P.S.I.  
RES. 60 P.S.I.

STA = 75 P.S.I.  
FLOW = 1160 G.P.M.

NOTE. ALL 6" VALS OPEN RT.  
ALL 2" VALS OPEN LT.  
F HYDS. TO BE 3-WAY & OPEN RT.

MATERIAL LIST:

6" D. I. Pipe	-	100.00
2" Galv. Pipe	-	20.00
6" Valves	-	4
2" Valves	-	1
Fire hydrants	-	2

✓ *job*  
**TERRA OAKS**  
DEC., 1979 SCALE 1" = 400'

*Subdivided for*  
*1981*  
*540.20-1-1 thru 20*

Commissioners of Public Works  
of the City of Greenville, S. C.  
November 5, 1980  
*voided*

RECORDED NOV 24 1980  
at 1:51 P.M.

15855

0.80

4328 RV-2