



BOOK 1155 PAGE 253



0
2
5
3

NOTE 6" VALVES OPEN RIGHT, 2" VALVE OPENS LEFT, FIRE HYDRANT TO BE 3-WAY & OPEN RIGHT.

Balentine Brothers Builders, Inc.
to
Commissioners of Public Works
of the City of Greenville, S. C.
August 19, 1981
BLK. Book 541.1-1-14

STATIC = 95 PSI.
FLOW = 1300 GPM.

STATIC = 86 PSI.
RES = 74 PSI.

Material List

6" D. I. Pipe	-	1,255'±
6" Valves	-	2
2" Valves	-	2
Fire Hydrant	-	1

NORTHWOOD SEC. I ADD.
AUG 1981 SCALE 1" = 400'

RECORDED SEP 17 1981 at 2:40 P.M.

7115

4328 RV-2