



STA = 108 P.S.I.
FLOW = 1300 G.P.M.

STA = 92 P.S.I.
RES = 81 P.S.I.

NOTE: 6" VALVES OPEN RIGHT
2" VALVES OPEN LEFT
FIRE HYDRANT TO BE
3-WAY & OPEN RIGHT

✓ Easement
American Service Corp. of S. C.
to
Commissioners of Public Works
of the City of Greenville, S. C.
April 6, 1982
Block Book 33-1-9

200 PARK AVE. CONDOMINIUMS

AUGUST, 1981 SCALE 1" = 100'
REVISED MARCH, 1982

RECORDED APR 26 1982
at 3:47 P.M.

235-18

0917

4328 RV.2