



STA=102 PSI
RES = 75 PSI

STA=100 PSI
FLOW=2010 GPM

EASEMENT
 Southern U. S. Realty Corporation
 to
 Commissioners of Public Works
 of the City of Greenville, S. C.
 August 10, 1984
 Blk. Book 539.5-1-64
 & 539.1-1-13

NOTE: 6" & 8" VALVES OPEN RIGHT
 2" VALVES OPEN LEFT
 FIRE HYDRANTS TO BE
 3-WAY & OPEN RIGHT

RECORDED SEP 6 1984 at 4:04 P.M.

7570

FOREST LAKE
 AUG, 1984 SCALE: 1" = 400'